

PERFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. U3116127S39142806

Dated: 14/09/2026

It is certified that an inspection team headed by **Shalini Shukla, Lab Incharge, District Level Water Analysis Laboratory, Sitapur** (Name of officers with designation) from **UP Jal Nigam (Rural) Sitapur** (Name of Department/office) Inspected the **Shail Memorial College , Ataria - Mau, Sidhauli Sitapur , Uttar Pradesh 261303** (Name & Address of the school) on **09-09-2026** (Date of inspection) and on the basis of water test report (Attached) Report no. **U3116127S39142806** dated **09-09-2026** of **District Level Water Analysis Laboratory, Sitapur (PHED)** lab certified that the **Shail Memorial College , village - Mau, Sidhauli Sitapur , Uttar Pradesh 261303** (Name of school) has safe drinking water facilities for the students and member of staff of the institution. School is also maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central /state /U.T. Govt.

Note:

This certificate is valid till **01 Year** from date of issue. In case, if there is any change in Drinking Source/gone under maintenance before Expiry of certificate, then this certificate will be no more valid. School will also need to maintain same water source condition. So to avoid this problem School is advice to send Drinking Water Sample on Regular Interval to District Level Water Analysis Laboratory, Sitapur.

Signature with Seal.....

Name **PAWAN KUMAR**.....Designation.....**A.E.**.....

Name & Address of the office/Department

Arya Nagar Water Tank Sitapur

To

Shail Memorial College**Village - Mau, Sidhauli Sitapur , Uttar Pradesh 261303**

(Name & Address of the institution)



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India
Address : Arya Nagar Water Tank , Sitapur

Rept No U3101232S38961451 Date 14-09-2026 Page No. 1

Customer Name SHAIL MEMORIAL COLLEGE

Basic details of sample

District	SITAPUR	Block	Sidhauri
Gram Panchayat	Ataria - Mau	Village/Mohalla	Mau
Habitation	Mau	Location/Site Name	School Campus Area
Water Source	Borewell	Sample No.	49057
Quantity of Sample	1L	Date of Sample Collection	09-09-2026
Receiving Date	09-09-2026	Sample Collector	Swant Mishra
Sample Depositer	Swant Mishra	Sampling Method	17614 Part 01
Analysis Start Date	09-09-2026	Analysis Completion Date	14-09-2026

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	pH @25°C	-	7.86	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
2	Turbidity	(NTU)	0.30	1	5	IS 3025 (Part 10) : 2023
3	TDS	(mg/L)	320	500	2000	IS 3025 (Part 16) : 2023
4	Chloride	(mg/L)	26	250	1000	IS 3025 (Part 32): 2019
5	Total Alkalinity	(mg/L)	300	200	600	IS 3025 (Part 23) : 2023
6	Total Hardness	(mg/L)	192	200	600	IS 3025 (Part 21) : 2019
7	Calcium	(mg/L)	28.8	75	200	IS 3025 (Part 40) : 2023
8	Magnesium	(mg/L)	29.16	30	100	IS 3025 (Part 46) : 2023
9	Sulphate	(mg/L)	BDL	200	400	APHA 24 Edition -4500 SO4 method (Turbidity method):2023
10	Nitrate	(mg/L)	1.11	45	45	APHA 24 Edition -4500 NO3 method B (UV Spectrophotometric method:2023)
11	Fluoride	(mg/L)	0.38	1	1.5	APHA 24 Edition -4500-F Method C (Electrode Method) : 2023
12	Iron	(mg/L)	BDL	1	No relaxation	APHA 24 Edition -3500-Fe Method B (Phenanthroline Method) : 2023
13	Color	Hazen	<5	5	15	IS 3025 (Part 4): 2021

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.
5. BDL Stands for Below Deduction Line that means water is in safe range.

Prepared By

Aastha Pandey
Lab Assit.

Authorized Signatory

Shalini Shukla
Chemist

Shalini Shukla

LAB INCHARGE

Laboratory Contact details :- Email - stplabupjalnigam@gmail.com , Mob :- +91 9580909869

District Level Water Analysis Laboratory
UPJN (RURAL), SITAPUR

End of the report



Analysis Report
District Level Water Analysis Laboratory
U.P Jal Nigam (Rural), SITAPUR, Uttar Pradesh, India

Rept No	U3101232S38961451	Date	14-09-2026	Page No.	1
---------	-------------------	------	------------	----------	---

Customer Name	SHAIL MEMORIAL COLLEGE
---------------	------------------------

Basic details of sample

District	SITAPUR	Block	Sidhauri
Gram Panchayat	Ataria - Mau	Village/Mohalla	Mau
Habitation	Mau	Location/Site Name	School Campus Area
Water Source	Borewell	Sample No.	49057
Quantity of Sample	1L	Date of Sample Collection	09-09-2026
Receiving Date	09-09-2026	Sample Collector	Swant Mishra
Sample Depositer	Swant Mishra	Sampling Method	17614 Part 01
Analysis Start Date	09-09-2026	Analysis Completion Date	14-09-2026

Technical Data of Analysis

S.No.	Analysed Parameter	Units	Observed Value	Specified Values as per IS 10500:2012		Ref. Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	E.coli	-	0.0	Shall Not Be Deducted in 100 ml sample		APHA 24th Edition -9211B
2	T.coli	-	0.0	Shall Not Be Deducted in 100 ml sample		APHA 24th Edition -9211B

Note

1. This Certificate refers only to the particular sample(s) submitted for testing.
2. This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

Prepared By

Microbiologist

Authorized Signatory

Microbiologist
Saumya Gupta

Laboratory Contact details -: Email - stplabupjalnigam@gmail.com , Mob -: +91 8318597887

End of the report