



**NOTES :-**

1. ALL DIMENSIONS ARE IN M.M.
2. DESIGN STANDARD BS EN 40-3-1&3
3. DESIGN CRITERIA :
  - 3.1. BASIC WIND SPEED - IS : 875 PART III : 1987
  - 3.2. DESIGN LIFE - 25 YEARS.
  - 3.3. TERRAIN CATEGORY - 2
  - 3.4. TOPOGRAPHY - FLAT
4. MATERIALS :
  - 4.1. SHAFT: S355 AS PER BS EN 10025.
  - 4.2. FLANGE: AS PER IS-2062.
  - 4.3. FOUNDATION BOLTS : EN8 GRADE
5. FINISHING : HOT DIP GALVANIZED TO BS EN ISO 1461.
6. MAKE OF THE POLE "BAJAJ".



TOLERANCES :-	
DIAMETERS A/F	± 2.5 %
POLE TOTAL LENGTH	± 1.2 %
POLE STRAIGHTNESS	± 0.3 %

This drawing is the property of "BAJAJ ELECTRICALS LTD." & must be returned on request. It is submitted as confidential information in connection with enquiry, tenders, orders or contracts. It is not to be used for any other purpose or order nor may it re-copied or lent without our authority in writing.

CLIENT	TURNING POINT		
PROJECT	STREET LIGHTING		
CONTRACTOR	*****		
MANUFACTURER			
TITLE	GA DRAWING OF 7M OCTAGONAL POLE WITH 1M SWORD TYPE DA BRACKET		DATE 24.07.2018
DRWN BY	NZR	JOB NO.	DRG. NO.
DSGD BY	HVR	1511807120	EPC-SL-18-1511807120-003
CHKD BY	VA		
REV	DATE	REVISION	APPRD
03			APPRD BY CSM
02			
01	30.07.2018	REVISED AS PER COMMENTS	