

FORM U-1 MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS

PO# _____

As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

Tag and/or Project _____

1. Manufactured and certified by Taylor Forge Engineered Systems, Inc., 6333 N. Erie Ave., Tulsa, Oklahoma, 74117, USA
(Name and address of Manufacturer)

2. Manufactured for KP ENGINEERING, 5555 OLD JACKSONVILLE HWY, TYLER, Texas, 75703, USA
(Name and address of Purchaser)

3. Location of installation UNKNOWN
(Name and address)

4. Type Horizontal HEAT EXCHANGER 1203-03
(Horizontal, vertical, or sphere) (Tank, separator, jkt. vessel, heat exch., etc.) (Manufacturer's serial number)

N/A 1203-03-A1 REV 5 3039 2016
(CRN) (Drawing number) (National Board number) (Year built)

5. ASME Code, Section VIII, Div. 1 2015/ N/A N/A N/A
[Edition and Addenda, if applicable (date)] (Code Case Number) [Special Service per UG-120(d)]

Items 6-11 incl. to be completed for single wall vessels, jackets of jacketed vessels, shell of heat exchangers, or chamber of multichamber vessels.

6. Shell: (a) Number of course(s) 3 (b) Overall length 20' 1.375"

Course(s)			Material	Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A, B, & C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
2	26.0" ID	8' 0.125"	SA516-70	.500"	0.125"	1	SPOT	.85	1	SPOT	.85	N/A	N/A
1	26" ID	4' 0.625"	SA516-70	.500"	0.125"	1	SPOT	.85	1	SPOT	.85	N/A	N/A

Body Flanges on Shells

No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material
1	RFWN	26.0"	32.250"	3"	1/2"	SA105	WELDED	END	24 - 1-1/8"	SA193B7	N/A	N/A

7. Heads: (a) SA516-70 (b) N/A
(Material spec. number, grade or type) (H.T. - time and temp.) (Material spec. number, grade or type) (H.T. - time and temp.)

	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff.
(a)	END	0.355"	0.125"	N/A	N/A	2:1	N/A	N/A	N/A		X	S	None	NA
(b)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A			N/A	N/A	N/A

Body Flanges on Heads

No.	Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Bolting			
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material
(a)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		N/A	N/A	N/A

8. Type of jacket N/A Jacket closure N/A
(Describe as ogee & weld, bar, etc.)

If bar, give dimensions; if bolted, describe or sketch N/A

9. MAWP 364 psi -15 psi at max. temp. 150 °F 150 °F Min. design metal temp. -20 °F at 364 psi
(Internal) (External) (Internal) (External)

10. Impact test NO at test temperature of N/A
[Indicate yes or no and the component(s) impact tested]

11. Hydro., pneu., or comb. test pressure Hydro. at 474 psi Proof test N/A

Items 12 and 13 to be completed for tube sections.

12. Tubesheet (1) SA516-70N 27.6875" 2.50" 0.250" BOLTED
[Stationary (material spec. no.)] [Diameter (subject to press.)] (Nominal thickness) (Corr. allow.) Attachment (welded or bolted)

N/A N/A N/A N/A N/A
[Floating (material spec. no.)] (Diameter) (Nominal thickness) (Corr. allow.) (Attachment)

13. Tubes SA214 3/4" 0.109" 202 U
(Material spec. no., grade or type) (O. D.) (Nominal thickness) (Number) [Type (Straight or U)]

Items 14-18 incl. to be completed for inner chambers of jacketed vessels or channels of heat exchangers.

14. Shell: (a) No. of course(s) 1 (b) Overall length 0' 13.6875"

Course(s)			Material	Thickness		Long. Joint (Cat. A)			Circum. Joint (Cat. A, B, & C)			Heat Treatment	
No.	Diameter	Length	Spec./Grade or Type	Nom.	Corr.	Type	Full, Spot, None	Eff.	Type	Full, Spot, None	Eff.	Temp.	Time
1	26.0" ID	0' 13.6875"	SA516-70	0.500"	0.125"	1	SPOT	.85	1	SPOT	.85	1150°	1 HR

Body Flanges on Shells

No.	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Location	Bolting				
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material	
1	RFWN	26"	32.250"	2-5/8"	1/2"	SA105	WELDED	END	N/A	SA193-B7	N/A	N/A	N/A
1	RFWN	26"	32.250"	3"	1/2"	SA105	WELDED	END	N/A	SA193-B7	N/A	N/A	N/A

15. Heads: (a) FLAT HEAD SA105 (Material spec. number, grade or type) (H.T. - time and temp.) (b) N/A (Material spec. number, grade or type) (H.T. - time and temp.)

(a)	Location (Top, Bottom, Ends)	Thickness		Radius		Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure		Category A		
		Min.	Corr.	Crown	Knuckle					Convex	Concave	Type	Full, Spot, None	Eff.
	END	2.375"	0.125"	N/A	N/A	N/A	N/A	N/A	32-1/4"			N/A	N/A	N/A

Body Flanges on Heads

No.	Location	Type	ID	OD	Flange Thk	Min Hub Thk	Material	How Attached	Bolting				
									Num & Size	Bolting Material	Washer (OD, ID, thk)	Washer Material	
N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

16. MAWP 279 psi (Internal) -15 psi (External) at max. temp. 200 °F (Internal) 200 °F (External) Min. design metal temp. -20 °F at 279 psi

17. Impact test NO at test temperature of N/A [Indicate yes or no and the component(s) impact tested]

18. Hydro., pneu., or comb. test pressure Hydro. at 363 psi Proof test N/A

19. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain, etc.)	No.	Diameter or Size	Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
SH INLET	1	6"	RFWN	SA106B	SA105	0.378"	0.125"	INTEGRAL	UW16.1C	WELDED	
SH OUTLET	1	6"	RFWN	SA106B	SA105	0.378"	0.125"	INTEGRAL	UW16.1C	WELDED	
CH INLET	1	6"	RFWN	SA106B	SA105	0.378"	0.125"	INTEGRAL	UW16.1C	WELDED	
CH OUTLET	1	6"	RFWN	SA106B	SA105	0.378"	0.125"	INTEGRAL	UW16.1C	WELDED	
SH AUXILIARY	1	1"	RFWN	SA106B	SA105	0.250"	0.125"	INTEGRAL	UW16.1C	WELDED	
SH AUXILIARY	1	1"	RFWN	SA106B	SA105	0.250"	0.125"	INTEGRAL	UW16.1C	WELDED	
CH AUXILIARY	1	1"	RFWN	SA106B	SA105	0.250"	0.125"	INTEGRAL	UW16.1C	WELDED	
CH AUXILIARY	1	1"	RFWN	SA106B	SA105	0.250"	0.125"	INTEGRAL	UW16.1C	WELDED	

20. Supports: Skirt No (Yes or no) Lugs 5 (Number) Legs 2 (Number) Others N/A (Describe) Attached WELDED TO CHANNEL, SHELL AND COVER (Where and how)

21. Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report (list the name of part, item number, Manufacturer's name, and identifying number):

N/A

22. Remarks

Length of tubes: 20' 0"
IMPACTS EXEMPT PER UG-20 (f) AND UCS-66
over pressure protection per UG-125 (a) (2)

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. U Certificate of Authorization Number 47294 Expires March 12, 2017

Date 07/07/2016 Name Taylor Forge Engineered Systems, Inc. Signed [Signature]
(Manufacturer) (Representative)

CERTIFICATE OF SHOP INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and employed by

The Hartford Steam Boiler Inspection and Insurance Company of Connecticut, of Hartford, CT

have inspected the pressure vessel described in this Manufacturer's Data Report on June 3, 2016, and state that,

to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 07/07/2016 Signed [Signature] Commissions: 11448AB, OK713
(Authorized Inspector) [National Board (incl. endorsements)]

CERTIFICATE OF FIELD ASSEMBLY COMPLIANCE

We certify that the statements made in this report are correct and that the field assembly construction of all parts of this vessel conforms with the requirements of ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. U Certificate of Authorization Number _____ Expires _____

Date _____ Name _____ Signed _____
(Assembler) (Representative)

CERTIFICATE OF FIELD ASSEMBLY INSPECTION

I, the undersigned, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and employed by _____,

have compared the statements in this Manufacturer's Data Report with the described pressure vessel and state that parts referred to as data items _____, not included in the certificate of shop inspection, have been inspected by me and to the best of my knowledge and belief, the Manufacturer has constructed and assembled this pressure vessel in accordance with the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. The described vessel was inspected and subjected to a hydrostatic test of _____. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date _____ Signed _____ Commission _____
(Authorized Inspector) [National Board (incl. endorsements)]