

FORM R-1 REPORT OF REPAIR
in accordance with provisions of the *National Board Inspection Code*

[Signature]
(Authorized Rep. initials)
[Signature]
(Inspectors initials)

(Form "R" Registration no.)
200840
(P.O. no., job no., etc.)

1. WORK PERFORMED BY: Tiger Industries, Inc.
(name of repair organization)
8909 JACKRABBIT RD, SUITE B HOUSTON, TX 77095
(address)

2. OWNER: Tiger Industries, Inc.
(name)
8909 JACKRABBIT RD, SUITE B HOUSTON, TX 77095
(address)

3. LOCATION OF INSTALLATION: Unknown
(name)

(address)

4. ITEM IDENTIFICATION: Air Cooled Heat Excha NAME OF ORIGINAL MANUFACTURER: SmithCo Engineering, Inc.
(boiler, pressure vessel, or piping)

5. IDENTIFYING NOS: 95B-1321-A 6428 1995
(mfg. serial no.) (National Board no.) (jurisdiction no.) (other) (year built)

6. NBIC EDITION/ADDENDA: 2021
(edition) (addenda)

Original Code of Construction for Item: ASME Section VIII, Division I 1992 / A93
(name / section / division) (edition / addenda)

Construction Code Used for Repair Performed: ASME Section VIII, Division I 2021
(name / section / division) (edition / addenda)

7. REPAIR TYPE: welded graphite pressure equipment FRP pressure equipment DOT

8. DESCRIPTION OF WORK: Form R-4, Report Supplementary Sheet is attached FFSA Form (NB-403) is attached
(use Form R-4, if necessary)

Replaced old flanges on inlet and outlet nozzles with new identical flanges.

Hydro-Static _____ Pressure Test, if applied 225 _____ psi MAWP 150 _____ psi
(Liquid, Pneumatic, Vacuum, Leak)

9. REPLACEMENT PARTS: (Attached are Manufacturer's Partial Data Reports or Form R-3's properly completed for the following items of this report):
(name of part, item number, data report type or Certificate of Compliance, mfg's. name and identifying stamp)

10. REMARKS:

(Form "R" Registration no.)

200840

(P.O. no., job no., etc.)

CERTIFICATE OF COMPLIANCE

I, Austin Karl, certify that to the best of my knowledge and belief the statements made in this report are correct and that all material, construction, and workmanship on this Repair conforms to the *National Board Inspection Code*. National Board "R" Certificate of Authorization No. R-8878 Expiration date: October 26, 2024

Repair Organization: Tiger Industries, Inc.


Signed: 
(authorized representative)

Date: 1-31-24

CERTIFICATE OF INSPECTION

I, John Washington, holding a valid commission issued by The National Board of Boiler and Pressure Vessel Inspectors and certificate of competency, where required, issued by the Jurisdiction of TX and employed by TUV Rheinland AIA Services of Houston, TX have inspected the work described in this report on January 31st, 2024 and state that to the best of my knowledge and belief, this work complies with the applicable requirements of the *National Board Inspection Code*. By signing this certificate, neither the undersigned nor my employer makes any warranty, expressed or implied, concerning the work described in this report. Furthermore, neither the undersigned nor my employer shall be liable in any manner for any personal injury, property damage, or loss of any kind arising from or connected with this inspection.

Commissions: NB 8600A P.P. TX 925
(National Board and Jurisdiction no. including endorsement)

Signed: 
(inspector)

Date: 1-31-24

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by SMITHCO Engineering, Inc., 6211 S. 39th W. Ave., Tulsa, OK 74132
(Name and address of manufacturer)

2. Manufactured for ALLEN TANK, INC. NEW IBERIA, LA 70562
(Name and address of purchaser)

3. Location of installation ALLEN TANK, INC. UNKNOWN
(Name and address)

4. Type Horiz(Non-Cir) 95B-1321-A 95B-1321 6428 1995
(Horizontal or vertical tank) (Mfr's serial No.) (CFR) (Drawing No.) (Part No.) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE.
 The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1992
Year

to A93
Addenda (Date)

6. Shell, Tube & Plug Sheets SA-516 GR-70 Fr 1.000/Bk 1.000 1250 Fr 0' 7.8750"/Bk 0' 7.8750" 12' 6.1250"
Matl (Spec No. Grade) Nom Thk (in) Corr Allow (in) Diam I.D. (ft. & in) Length (overall) (ft. & in)

7. Seams: Corner Joint 100 1100 30min. 1
Long (Welded Dtl Spig. Lap. Butt) R.T. (Spot or Full) ERT% H.T. Temp. (F) Time (hr) Girth (Welded Dtl Spig. Lap. Butt) R.T. (Spot Partial or Full) No. of Courses

8. Heads: (a) Matl. (a) Covers: SA-516 GR-70 (b) Matl. (b) Ends: SA-516 GR-70
(Spec No. Grade) (Spec No. Grade)

	Location (Top Bottom Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemispherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	Fr/Bk	375/375	1250						2.1250/2.1250 x 150.1250	Flat
(b)	Fr/Bk	375/375	1250						2.1250/2.1250 x 7.3750/7.3750	Flat

If removable, bolts used (describe other fastenings) _____
(Matl. Spec No. Gr. Size, No.)

9. MAWP 150 psi at max. temp. 250 °F
 Min. design metal temp. -20 °F at 150 psi. Hydro. pneu. or comb. test pressure 225 psi

10. Nozzles, inspection and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No	Diameter or Size	Type	Material	Nominal Thickness	Reinforcement Material	How Attached	Location
Inlet/Outlet	2/2	3" 150/160	RFWN	SA-105/	.438	Weld Metal	Welded	Front Head
Vent/Drain	2	1.0/1.0	6000CPLG	SA-105		Weld Metal	Welded	Back Head

11. Supports: Skirts No Lugs (No) Legs 4 Other (Describe) Attached Welded to covers
(Yes or No) (No) (No) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:

(Name of part, item number, Mfr's name and identifying stamp)

Impact testing exempt per: UG-20(f) Item: HAL-7650 Service: LEAN AMINE COOLER
 Tubes: SA-214 WLD- 258 x 1.00" x .065" x 32.0000'-Straight

CERTIFICATE OF SHOP COMPLIANCE	
We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. <u>4175</u> expires <u>February 28th</u> , 19 <u>97</u> .	
Date <u>10-10-95</u> Co. name <u>SMITHCO Engineering, Inc.</u> Signed <u>J. Copeland</u>	<small>(Manufacturer) (Representative)</small>
CERTIFICATE OF SHOP INSPECTION	
Vessel constructed by <u>SMITHCO Engineering, Inc.</u> at <u>Tulsa, Oklahoma</u>	
I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of <u>Oklahoma</u> and employed by <u>Delta Lloyds Insurance Company - Houston, Texas</u>	
have inspected the component described in this Manufacturer's Data Report on <u>10-12</u> 19 <u>95</u> , and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or loss of any kind arising from or connected with this inspection.	
Date <u>10-12-95</u> Signed <u>[Signature]</u> Commissions <u>NB7003.A, OK355</u>	<small>(Authorized Inspector) (Natl. Board (incl. endorsements), State, Prov. and No.)</small>