

190609

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
(Alternative Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by HAPPY DIVISION, THERMA TECH., INC. 5500 E. INDEPENDENCE TULSA, OKLA. 741
(Name and address of manufacturer)

2. Manufactured for Becon Construction Co. 5400 Westheimer Ct. Houston, Texas 77056
(Name and address of purchaser)

3. Location of installation Amoco/Anschutz Ranch East Nitrogen Plant Evanston, Wyoming
(Name and address)

4. Type HORIZ. 4425-1-1J --- 4425-1-20 2304 1986
(Mount or vent tank) (Mfg's serial No 1) (CRN) (Drawing No 1) (Heat No No 1) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1983
Yes

to 12-31-84
Expiry Date

* 6. Wrapper: SA-516-70 --- --- --- --- --- --- ---
Matl (Spec No., Grade) Name, Thk., Len. Corr. Allow. Len. Width Length (overall) Lts. & in.

7. Seams: Welded No --- --- --- --- --- --- ---
Long (Welded, Dbl., Spd., Lap, Butt) R.T. (Spot, Patch, or Full) E.T. (S) H.T. Temp. (F) Temp. (F) Corr. (Welded, Dbl., Spd., Lap, Butt) R.T. (Spot, Patch, or Full) No. of Courses

8. Heads: (a) Matl. SA-516-70 (b) Matl. SA-516-70
(Spec No., Grade) (Spec No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Max. Span	Flat Dimension	Safe to Pressure (Cutters or Cuts etc)
(a)	T&P Sht.					Flat
(b)	End Block					Flat

If removable, bolts used (describe other fastenings) _____
(Matl., Spec No., Gr., Size, No.)

9. MAWP 260 psi at max. temp. 200 °F
Min. temp. (when less than -20°F) _____ °F. Hydro. 390 DSI

10. Nozzles, inspection and safety valve openings: **** All Noz. Pipe SA-106-B**

Purpose (Inlet, Outlet, Drain)	No	Dim or Size	Type	Matl	Num Thk	Reinforcement Matl	How Attached	Is closed
INLET	2	6" 150#	RF WN	SA-105	Sch 80	NONE	WELDED	HEADER
OUTLET	2	3" 150#	RF WN-	SA-105	Sch XH	NONE	WELDED	HEADER
						NONE	WELDED	HEADER
						NONE	WELDED	HEADER

11. Supports: Skirt No Lugs 4 Legs --- Other --- Attached Welded to Tube Sheet
(Yes or no) (No.) (No.) (Describe) (Where and how)

12. Remarks: Box Header at Tube Ends 4 Row, 4 Pass, Tube Material: SA-214
Qty. 266 O.D. 1" x .075M x 48'-0" Long.

*See Attached U-4 Form

REGTEL

157

Unit Service: Refrigerant Condenser Item No. 68-2901-9

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of this vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 10,491 expires May 11, 1986.
Date 3-14-86 Co. name HAPPY DIVISION, THERMA TECH, INC. Signed _____ (Required)

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by HAPPY DIVISION, THERMA TECHNOLOGY, INC. TULSA, OKLAHOMA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of OKLAHOMA and employed by COMMERCIAL UNION INSURANCE CO.
have inspected the component described in this Manufacturer's Data Report on 4-18-86, 19 86, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.
Date 4-23-86 Signed Mark Stanford Commissions 91B-8741 OK-267
(Author and Inspector) (National Board and State, Province and No.)

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by HAPPY DIVISION, THERMA TECH. INC. 5500 E. INDEPENDENCE TULSA, OKLA. 74115
(Name and address of manufacturer)

2. Manufactured for Becon Construction Co. 5400 Westheimer Ct. Houston, Texas 77056
(Name and address of purchaser)

3. Location of installation Amoco/Anschutz Ranch East Nitrogen Plant Evanston, Wyoming
(Name and address)

4. Type HORIZ. 4425-1-1J 4425-1-20 2304 1986
(Material, Item No.) (ICR#) (Qty) (Part No.) (Year built)

Data Report
 Item Number Remarks

LOCATION	Matl.	Nom. Thk.	Corr. All.	Wdrh.	Lenh.
* WRAPPER	SA-516-70	5/8"	.0625"	5 3/4"	14'-8 3/4"
INLET	SA-516-70	1/2"	.0625"	3 3/4"	14'-8 3/4"
RETURN					

* T&P Sht.	Min. Thk.	Corr. All.	Max. Span	Flat Dim.	Side To Press
INLET	1"	.0625"	8 7/8"	10" x 14'-8 3/4"	Flat
RETURN	1"	.0625"	9 1/8"	10" x 14'-8 3/4"	Flat

* END BLOCK	Min. Thk.	Corr. All.	Max. Span	Flat Dim.	Side To Press
INLET	5/8"	.0625"	6 1/8"	5 7/8" x 8 1/2"	Flat
RETURN	1/2"	.0625"	4 1/8"	3 7/8" x 8 3/4"	Flat

RECHTEN
152

Item No: G8-2901-1J

Date 3-14-86 Co. name HAPPY DIVISION, THERMA TECH. Signed [Signature]
U-97-86 [Signature] 1978-8741 OK-26