

190615

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop-Fabricated Vessels Only)
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by HAPPY DIVISION, THERMA TECH., INC. 5500 E. INDEPENDENCE TULSA, OKLA. 7
(Name and address of manufacturer)

2. Manufactured for Becon Construction Co. 5400 Westheimer Ct. Houston, Texas 77056
(Name and address of purchaser)

3. Location of installation Amoco/Anschutz Ranch East Nitrogen Plant Evanston, Wyoming
(Name and address)

4. Type HORIZ. 4425-1-1C 4425-1-20 2295 1986
(Material or shell design) (Shell Symbol No. 1) (ICR No.) (Shell Symbol No. 2) (Shell Bl. No. 1) (Shell Bl. No. 2)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Division 1 1983
(Year)

to 12-31-84
(Effective Date)

* s. Wrapper:

7. Seams: Welded No Width Welded No
(Type of Seam) (Type of Seam) (Type of Seam) (Type of Seam) (Type of Seam) (Type of Seam)

8. Heads: (a) Matl. SA-516-70 (b) Matl. SA-516-70
(Spec. No., Grade) (Spec. No., Grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Max. Span	Flat Dimension	Notes by Purchaser (Comments on Construction)
(a)	T&P Sht.					
(b)	End Block				Flat	Flat

If removable, bolts used (describe other fastenings): _____

9. MAWP 260 psi at max. temp. 200
 Min. temp. (when less than -20°F) _____ °F, Hydro. 390

10. Nozzles, inspection and safety valve openings: **** ATT Noz. Pipe SA-106-B**

Purpose (Inlet, Outlet, Drain)	No.	Diem. or Size	Type	Matl.	Nom. Thk.	Reinforcement Matl.	How Attached	Attachment
INLET	2	6" 150#	RF WN	SA-105	Sch 80	NONE	WELDED	HEADER
OUTLET	2	3" 150#	RF WN-	SA-105	Sch XH	NONE	WELDED	HEADER
						NONE	WELDED	HEADER
						NONE	WELDED	HEADER

11. Supports: Skirt No Legs 4 Legs _____ Other _____ Attached Welded to Tube Sheet
(Vertical) (No.) (No.) (Diagonal) (Where and how)

12. Remarks: Box Header at Tube Ends 4 Row, 4 Pass, Tube Material: SA-214
Qty. 266 O.D. 1" x .075M x 48'-0" Long.

*See Attached U-4 Form

Unit Service: Refrigerant Condenser Item No. G8-2901-3

CERTIFICATE OF SHOP COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction, and workmanship of the vessel conform to the ASME Code for Pressure Vessels, Section VIII, Division 1. "U" Certificate of Authorization No. 10,491 expires May 11, 1986
 Date 3-14-86 Co. name HAPPY DIVISION, THERMA TECH, INC. Signed _____

CERTIFICATE OF SHOP INSPECTION

Vessel constructed by HAPPY DIVISION, THERMA TECHNOLOGY, INC. TULSA, OKLAHOMA

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of OKLAHOMA and employed by COMMERCIAL UNION INSURANCE CO.

have inspected the component described in this Manufacturer's Data Report on 4-8, 1986, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME Code, Section VIII, Division 1. By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 4-17-86 Signed [Signature] Commissions MB8741 OK-767
(Approved Inspector) (National Board Unit - Department, State, Province and No.)

FORM U-4 MANUFACTURER'S DATA REPORT SUPPLEMENTARY SHEET
 As Required by the Provisions of the ASME Code Rules, Section VIII, Division 1

1. Manufactured and certified by HAPPY DIVISION, THERMA TECH. INC. 5500 E. INDEPENDENCE TULSA, OKLA. 74115
(Name and address of manufacturer)

2. Manufactured for Becon Construction Co. 5400 Westheimer Ct. Houston, Texas 77056
(Name and address of purchaser)

3. Location of installation Amoco/Anschutz Ranch East Nitrogen Plant Evanston, Wyoming
(Name and address)

4. Type HORIZ. 4425-1-1C 4425-1-20 2295 1986
(Material, thickness, ID, OD, Shell ID No. 1, Year built)

Data Report
Item Number

Remarks

LOCATION	Matl.	Nom. Thk.	Corr. All.	Wdrh.	Lenh.
* WRAPPER	SA-516-70	5/8"	.0625"	5 3/4"	14'-8 3/4"
INLET	SA-516-70	1/2"	.0625"	3 3/4"	14'-8 3/4"
RETURN					

* T&P Sht.	Min. Thk.	Corr. All.	Max. Span	Flat Dim.	Side To Press
INLET	1"	.0625"	8 7/8"	10" x 14'-8 3/4"	Flat
RETURN	1"	.0625"	9 1/8"	10" x 14'-8 3/4"	Flat

* END BLOCK	Min. Thk.	Corr. All.	Max. Span	Flat Dim.	Side To Press
INLET	5/8"	.0625"	6 1/8"	5 7/8" x 8 1/2"	Flat
RETURN	1/2"	.0625"	4 1/8"	3 7/8" x 8 3/4"	Flat

RECEIVED
157

Item No. 68-2901-3

Date 3-14-86

Co. Name HAPPY DIVISION, THERMA TECH.

Signed [Signature]