

FORM U-1A MANUFACTURER'S DATA REPORT FOR PRESSURE VESSELS
 (Alternative Form for Single Chamber, Completely Shop or Field Fabricated Vessels Only)

CORRECTED COPY
09/04/2013

As Required by the Provisions of the ASME Boiler and Pressure Vessel Code Rules, Section VIII, Division 1

1. Manufactured and certified by R & R Engineering Co., Inc., 12585 East 61st Street, Broken Arrow, OK 74012
(Name and address of Manufacturer)

2. Manufactured for ANADARKO E&P ONSHORE LLC THE WOODLANDS, TX 77387-4995
(Name and address of Purchaser)

3. Location of installation Unknown
(Name and address)

4. Type VERT. T-487.1 N/A T-487 3716 2013
(Horizontal or vertical, tank) (Manufacturer's serial number) (CUV) (Drawing number) (National Board Number) (Year built)

5. The chemical and physical properties of all parts meet the requirements of material specifications of the ASME BOILER AND PRESSURE VESSEL CODE. The design, construction, and workmanship conform to ASME Rules, Section VIII, Div. 1. 2010
Year

to 2011A None None
(Addenda (date)) (Code Case numbers) (Special service per UG-120(d))

6. Shell N/A N/A N/A N/A N/A N/A
(Material spec. number, grade) (Nominal thickness) (Corr. allow.) (Inner diameter) (Length (overall))

7. Seams Corner Joint N/A 100 N/A N/A N/A N/A N/A --- ---
(Long. (welded, dbl., engl., lap, butt)) (R.T. (spot or full)) (Eff., %) (H.T. temp. (°F)) (Time, hr) (Girth (welded, dbl., engl., lap, butt)) (R.T. (spot or full)) (Eff., %) (No. of courses)

8. Heads: (a) Material SA516-70 (b) Material SA516-70
(Spec. no., grade) (Spec. no., grade)

	Location (Top, Bottom, Ends)	Minimum Thickness	Corrosion Allowance	Crown Radius	Knuckle Radius	Elliptical Ratio	Conical Apex Angle	Hemi-spherical Radius	Flat Diameter	Side to Pressure (Convex or Concave)
(a)	T & P Sheet	3/4"	1/8"	Max	Span	5 3/8"	--	--	6 5/8"	53 7/8"
(b)	Wrap & Ends	5/8"	1/8"	Max	Span	2 7/8"	--	--	3 1/8"	59 1/4"

If removable, bolts used (describe other fastenings) 276 PCS 3/4"X16 SHOULDER STEEL PLUGS SA105
(National spec. number, grade, size, number)

9. MAWP 400 N/A psi at max temp. 300 N/A °F.
(Internal) (External) (Internal) (External)

Min. design metal temp. -20 °F at 400 psi. Hydro., pneu., or comb. test pressure 520 psi.

Proof Test N/A.

10. Nozzles, inspection, and safety valve openings:

Purpose (Inlet, Outlet, Drain)	No.	Diameter or Size	Type	Material		Nozzle Thickness		Reinforcement Material	Attachment Details		Location (Insp. Open.)
				Nozzle	Flange	Nom.	Corr.		Nozzle	Flange	
Inlet	1	3" 300	RFWN	SA106-B	SA105	Sch-160	1/8"	Weld	UW-16.1(a)	Welded	Head
Outlet	1	3" 300	RFWN	SA106-B	SA105	Sch-160	1/8"	Weld	UW-16.1(a)	Welded	Head

11. Supports: Skirt NO Lugs N/A Legs N/A Other Channels Attached Welded to 1 Header
(Yes or no) (Number) (Number) (Describe) (Where and how)

12. Remarks: Manufacturer's Partial Data Reports properly identified and signed by Commissioned Inspectors have been furnished for the following items of the report:
138 Pcs 5/8"X16 Ga SA214 Steel Tubes 6'0" Long
(Name of part, item number, Manufacturer's name and ident/leg stamp)

Exempt from Impact Testing Per UG-20(f) and UCS-66. Constructed in conformance with Appendix 28

CERTIFICATE OF SHOP/FIELD COMPLIANCE

We certify that the statements made in this report are correct and that all details of design, material, construction and workmanship of this vessel conform to the ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. "U" Certificate of Authorization Number 10139 expires FEB. 28, 2015.

Date 09/04/2013 Co. Name R & R ENGINEERING CO., INC. Signed [Signature]
(Manufacturer) (Responsible)

CERTIFICATE OF SHOP/FIELD INSPECTION

Vessel constructed by R & R ENGINEERING CO., INC. at Broken Arrow, Oklahoma
 I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State or Province of Oklahoma and employed by HSB CT

have inspected the component described in this Manufacturer's Data Report on 7/19/13, and state that, to the best of my knowledge and belief, the Manufacturer has constructed this pressure vessel in accordance with ASME BOILER AND PRESSURE VESSEL CODE, Section VIII, Division 1. By signing this certificate neither the Inspector nor his/her employer makes any warranty, expressed or implied, concerning the pressure vessel described in this Manufacturer's Data Report. Furthermore, neither the Inspector nor his/her employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 10/8/13 Signed [Signature] Commissions UB147348/OK1196
(Authorized Inspector) (National Board (incl. endorsements), State, Province, and number)