

Product description

Tag #s for MPP bearing RTDs:

TE-68734
TE-68736
TE-68738
TE-68740
TE-68735
TE-68737
TE-68739
TE-68741



Note: even numbers applicable to RP-62670,
odd numbers applicable to RP-62671.

Item number: 56022413

TR10-2-0-I-S-C-1AF13-1-FS-030-C-F-X-C-1-P-00125-Z017

ANM03000595CA

TR10-2 Internal spring loaded RTD Assembly

Assembly description:	Industrial assembly configured	(O)
Unit of Measure:	Imperial (inch)	(I)
Spring design:	Self gripping spring	(S)
Electrical approval:	CSA Ex-proof Class 1 Division I	(C)
Connection head:	1/4000 F (Aluminum) w/Flame Path	(1AF)
Instrument x Conduit entry:	1/2 NPT x 3/4 NPT	(13)
Terminal block/Transmitter:	Crastin	(1)
Neck extension:	Nipple-Union-Nipple - Stainless steel	(FS)
N-Dimension:	3.0 inch (76 mm)	(030)
Measuring element:	Pt100, class A (IEC 60751)	(C)
Wiring configuration:	Dual 3-wire	(F)
Temperature range:	-100...+450 °C, wire wound	(X)
Tip construction:	General purpose	(C)
Sensor diameter:	1/4 inch / 0.250 inch (6.35 mm)	(1)
Sheath material:	Stainless steel 316 / 316 L (1.4401 / 1.4435)	(P)
A-Dimension:	1.25	(00125)
Certificates:	Without	(Z)
Approval tags:	Adhesive half-moon tag	(A)
Tagging:	No tag	(N)
Sheath construction:	MI-cable	(M)

Shell				
Particular Review & Comments shall not be issued to indicate other responsibility or liability for accuracy or compliance of this document or data for continued use or modification.				
Particular Order No.	PG-45702000			
Product Name	Shell/Tube Data			
Supply Tag Number(s)	RP-62670/RP-62671/TE-68734/TE-68736/TE-68738/TE-68740/TE-68735/TE-68737/TE-68739/TE-68741			
Process Code	Options Code	Design Code	Process Type Code	Special No.
DP0404	00	10	10	000
Initials/Date	Cable(s)			
Cable(s)	Accepted as Submitted - Final			
Cable(s)	Accepted with Comments. Incorporate comments (inserts only). If per call location a final Work May Proceed.			
Cable(s)	Review and Re-submit. Incorporate comments, If per call location Work May Proceed.			
Cable(s)	Review not required - Do not re-submit			
Cable(s)	Revised. Incorporate comments (inserts and updates). Work may NOT Proceed.			
Date	Site			

