

Product description

Tag #s for MPP casing RTD:
TE-68730
TE-68731



Item number: 56022414


Note: even numbers applicable to RP-62670,
odd numbers applicable to RP-62671.

TR10-2-0-I-S-C-1AF13-1-FS-030-C-F-X-C-1-P-00200-Z017

ANM03000670CA

TR10-2 Internal spring loaded RTD Assembly

Assembly description:	Industrial assembly configured	(O)
Unit of Measure:	Imperial (inch)	(I)
Spring design:	Self gripping spring	(S)
Electrical approval:	CSA Ex-proof Class 1 Division I	(C)
Connection head:	1/4000 F (Aluminum) w/Flame Path	(1AF)
Instrument x Conduit entry:	1/2 NPT x 3/4 NPT	(13)
Terminal block/Transmitter:	Crastin	(1)
Neck extension:	Nipple-Union-Nipple - Stainless steel	(FS)
N-Dimension:	3.0 inch (76 mm)	(030)
Measuring element:	Pt100, class A (IEC 60751)	(C)
Wiring configuration:	Dual 3-wire	(F)
Temperature range:	-100...+450 °C, wire wound	(X)
Tip construction:	General purpose	(C)
Sensor diameter:	1/4 inch / 0.250 inch (6.35 mm)	(1)
Sheath material:	Stainless steel 316 / 316 L (1.4401 / 1.4435)	(P)
A-Dimension:	2.00	(00200)
Certificates:	Without	(Z)
Approval tags:	Adhesive half-moon tag	(A)
Tagging:	No tag	(N)
Sheath construction:	MI-cable	(M)



Shell					
Particular Review is a service to assist in the selection of suitable equipment or materials to complete a job. It is not a design review and does not constitute a warranty.					
Particular Review No.	P-00222414				
Project Name	TR10-2-0-I-S-C-1AF13-1-FS-030-C-F-X-C-1-P-00200-Z017				
Project No.	68731				
Project Code	Options	Design	Material	Special	Notes
	Code	Code	Code	Code	
	001	001	001	001	
Particular Review	Accepted as Submitted - Final				
Particular Review	Accepted with Comments. Comments: comments only. Please see the comments in the Work Item.				
Particular Review	Review and Rebuild. Comments: comments only. Please see the comments in the Work Item.				
Particular Review	Review not required - Do not re-submit				
Particular Review	Revised. Comments: comments only and revision. Work may NOT proceed.				
Date	N/A				
APPROVED					
By: Jim Partridge on 10-22-2019, May 14, 2019					

